

STATEMENT OF BASIS

as required by LAC 33:IX.3109, for draft **Louisiana Pollutant Discharge Elimination System Permit No. LA0118966; AI 111355; PER20090001** to discharge to waters of the **State of Louisiana** as per LAC 33:IX.2311.

The **permitting authority** for the Louisiana Pollutant Discharge Elimination System (LPDES) is:

Louisiana Department of Environmental Quality
Office of Environmental Services
P. O. Box 4313
Baton Rouge, Louisiana 70821-4313

- I. THE APPLICANT IS:** H2O Systems, Inc
Penn Mill Lakes STF
845 Galvez Street
Mandeville, LA 70448
- II. PREPARED BY:** Rachel Davis
- DATE PREPARED:** April 7, 2009
- III. PERMIT ACTION:** reissue LPDES permit LA0118966, AI 111355; PER20090001

LPDES application received: March 23, 2009

EPA has not retained enforcement authority.

LPDES permit issued: July 1, 2004
LPDES permit expired: June 30, 2009

IV. FACILITY INFORMATION:

- A. The application is for the discharge of treated sanitary wastewater from a privately owned treatment works serving the Penn Mill Lakes Subdivision.
- B. The permit application does not indicate the receipt of industrial wastewater.
- C. The facility is located on Penn Mill Lakes Blvd approx 0.25 miles from intersection with Penn Mill Loop in Covington, St. Tammany Parish.
- D. The treatment facility consists of an extended aeration sewage treatment plant with chlorine disinfection.
- E. Outfall 001

Discharge Location: Latitude 30° 31' 30" North
Longitude 90° 9' 20" West

Description: treated sanitary wastewater

Expected Flow: 474 homes x 400 gallons/day/home = 0.19 MGD

Calculations for gallons per day, were based upon figures obtained from Chapter 15 of the State of Louisiana Sanitary Code, Department of Health and Hospitals, Office of Public Health.

Statement of Basis

LA0118966; AI 111355; PER20090001

Page 2

Type of Flow Measurement which the facility is currently using:
Continuous Recorder

V. RECEIVING WATERS:

The discharge is into a parish drainage ditch, thence into Horse Branch, thence into the Tchefuncte River in segment 040801 of the Lake Pontchartrain Basin. This segment is listed on the 303(d) list of impaired waterbodies.

The designated uses and degree of support for Segment 040801 of the Lake Pontchartrain Basin are as indicated in the table below^{1/}:

Degree of Support of Each Use						
Primary Contact Recreation	Secondary Contact Recreation	Propagation of Fish & Wildlife	Outstanding Natural Resource Water	Drinking Water Supply	Shell fish Propagation	Agriculture
Not Supported	Full	Not Supported	Full	N/A	N/A	N/A

^{1/}The designated uses and degree of support for Segment 040801 of the Lake Pontchartrain Basin are as indicated in LAC 33:IX.1123.C.3, Table (3) and the 2006 Water Quality Management Plan, Water Quality Inventory Integrated Report, Appendix A, respectively.

VI. ENDANGERED SPECIES:

The receiving waterbody, Subsegment 040801 of the Lake Ponchartrain Basin, has been identified by the U.S. Fish and Wildlife Service (FWLS) as habitat for the Gulf sturgeon, which is listed federally as a threatened species. However, this type of discharge is not listed in Section II.2 of the Implementation Strategy as requiring consultation with the U. S. Fish and Wildlife Service (FWS). Therefore, in accordance with the Memorandum of Understanding between the LDEQ and the FWS, no further informal (Section 7, Endangered Species Act) consultation is required. It was determined that the issuance of the LPDES permit is not likely to have an adverse effect on any endangered or candidate species or the critical habitat. The effluent limitations established in the permit ensure protection of aquatic life and maintenance of the receiving water as aquatic habitat.

VII. HISTORIC SITES:

The discharge is from an existing facility location, which does not include an expansion beyond the existing perimeter. Therefore, there should be no potential effect to sites or properties on or eligible for listing on the National Register of Historic Places, and in accordance with the 'Memorandum of Understanding for the Protection of Historic Properties in Louisiana Regarding LPDES Permits' no consultation with the Louisiana State Historic Preservation Officer is required.

VIII. PUBLIC NOTICE:

Upon publication of the public notice, a public comment period shall begin on the date of publication and last for at least 30 days thereafter. During this period, any interested persons may submit written comments on the draft permit and may request a public hearing to clarify issues involved in the permit decision at this Office's address on the first page of the statement of basis. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing.

Statement of Basis

LA0118966; AI 111355; PER20090001

Page 3

Public notice published in:

Local newspaper of general circulation

Office of Environmental Services Public Notice Mailing List

For additional information, contact:

Ms. Rachel Davis

Water Permits Division

Department of Environmental Quality

Office of Environmental Services

P. O. Box 4313

Baton Rouge, Louisiana 70821-4313

IX. PROPOSED PERMIT LIMITS:

Final Effluent Limits:

Subsegment 040801, Tchefuncte River and Tributaries, is listed on LDEQ's Final 2006 303(d) List as impaired for pathogen indicators and mercury. To date no TMDLs have been completed for this waterbody. A reopener clause will be established in the permit to allow for the requirement of more stringent effluent limitations and requirements as imposed by a TMDL. Until completion of TMDLs for the Lake Pontchartrain Basin, those suspected causes for impairment which are not directly attributed to the sanitary wastewater point source category have been eliminated in the formulation of effluent limitations and other requirements of this permit. Additionally, suspected causes of impairment which could be attributed to pollutants which were not determined to be discharged at a level which would cause, have the reasonable potential to cause or contribute to an excursion above any present state water quality standard were also eliminated.

Mercury

Based on the size and nature of the facility, the department believes there is little potential for the discharge to further cause or contribute to the mercury impairment of this subsegment. Therefore, no limitations for mercury will be required of this facility.

Pathogen Indicators

To protect against high levels of pathogenic organisms in the receiving waterbody, fecal coliform limits have been established in the general permit.

Outstanding Natural Resource Water

Tchefuncte River, Subsegment 040801, is a designated Outstanding Natural Resource Waterbody. Because the discharge is small and will be made into an unnamed ditch and flows 2 miles, through Horse Branch before reaching the Tchefuncte River, this discharge will not impact the waterbody. Furthermore, in accordance with LAC 33:IX.1119.C.4, existing discharges of treated sanitary wastewater are allowed if no reasonable alternative discharge location is available. Because there is no municipal or community sewage treatment available for this facility, no alternative discharge location is available.

Statement of Basis

LA0118966; AI 111355; PER20090001

Page 4

OUTFALL 001

Final limits shall become effective on the effective date of the permit and expire on the expiration date of the permit.

Effluent Characteristic	Monthly Avg. (lbs./day)	Monthly Avg.	Daily Max	Basis
CBOD ₅	16	10 mg/l	15 mg/l	Limits set in accordance with the Aerawide Policy for St. Tammany Parish and the previous permit
TSS	24	15 mg/l	23 mg/l	Since there is no numeric water quality criterion for TSS, and in accordance with the current Water Quality Management Plan, the TSS effluent limitations shall be based on a case-by-case evaluation of the treatment technology being utilized at a facility. Therefore, a Technology Based Limit has been established through Best Professional Judgement for the type of treatment technology utilized at this facility.
Ammonia-Nitrogen	8	5 mg/l	10 mg/l	Limits set in accordance with the Aerawide Policy for St. Tammany Parish and the previous permit
Dissolved Oxygen	---	5 mg/l	N/A	Limits set in accordance with the Aerawide Policy for St. Tammany Parish and the previous permit

*Concentration limits are used in accordance with LAC 33:IX.2709.F.1.b which states that mass limitations are not necessary when applicable standards and limitations are expressed in other units of measurement. LAC 33:IX.709.B references LAC 33:IX.711 which express BOD₅ and TSS in terms of concentration.

**This Dissolved Oxygen limit is the lowest allowable average of daily discharges over a calendar month. When monitoring is conducted, the Dissolved Oxygen shall be analyzed immediately, as per 40 CFR 136.3.

Other Effluent Limitations:**1) Fecal Coliform**

The discharge from this facility is into a water body which has a designated use of Primary Contact Recreation. According to LAC 33:IX.1113.C.5., the fecal coliform standards for this water body are 200/100 ml and 400/100 ml. Therefore, the limits of 200/100 ml (Monthly

Statement of Basis

LA0118966; AI 111355; PER20090001

Page 5

These limits are being proposed through Best Professional Judgement in order to ensure that the water body standards are not exceeded, and due to the fact that existing facilities have demonstrated an ability to comply with these limitations using present available technology.

2) pH

The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units at any time. (Limits as established through BPJ considering BCT for similar waste streams in accordance with LAC 33:IX.5905.C)

3) Solids and Foam

There shall be no discharge of floating solids or visible foam in other than trace amounts in accordance with LAC 33:IX.1113.B.7.

X. PREVIOUS PERMITS:

LPDES Permit No. LA0118966: Issued: July 1, 2004
Expired: June 30, 2009

<u>Effluent Characteristic</u>	<u>Discharge Limitations</u>		<u>Monitoring Requirements</u>	
	<u>Monthly Avg.</u>	<u>Weekly Avg.</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow	Report	Report	Continuous	Recorder
CBOD ₅	10 mg/l	15 mg/l	2/month	Grab
TSS	15 mg/l	23 mg/l	2/month	Grab
Ammonia-Nitrogen	5 mg/l	10 mg/l	2/month	Grab
Dissolved Oxygen	5 mg/l	---	2/month	Grab
Fecal Coliform Colonies	200	400	2/month	Grab

XI. ENFORCEMENT AND SURVEILLANCE ACTIONS:

A) Inspections

A review of the files indicates the following inspections were performed during the period beginning **January 2007** and ending **December 2008** for this facility.

Date: May 30, 2008

Inspector: Ella Barbe

Findings and/or Violations:

1. Plant received a large amount of mud, clay, and silt from area under development
2. Tertiary filter was not functioning
3. A recorder is being used, but no flow charts are being used as required by permit
4. NH₃N, CBOD, and TSS loadings aren't calculated by using actual 24 hr flows
5. DO and pH meter logs were not available

B) Compliance and/or Administrative Orders

A review of the files indicates that no compliance orders have been administered against the facility.

C) DMR Review

A review of the discharge monitoring reports for the period beginning **January 2007** through **December 2008** has revealed the following violations:

Statement of Basis

LA0118966; AI 111355; PER20090001

Page 6

Parameter	Outfall	Period of Excursion	Permit Limit	Reported Quantity
DO	001	December 2008	5	6.8
Fecal	001	December 2008	400	552

XII. ADDITIONAL INFORMATION:

The Louisiana Department of Environmental Quality (LDEQ) reserves the right to modify or revoke and reissue this permit based upon any changes to established TMDL's for this discharge, or to accommodate for pollutant trading provisions in approved TMDL watersheds as requested by the permittee and/or as necessary to achieve compliance with water quality standards. Therefore, prior to upgrading or expanding this facility, the permittee should contact the Department to determine the status of the work being done to establish future effluent limitations and additional permit conditions.

This permit may be modified, or alternatively, revoked and reissued, to comply with any applicable effluent standard or limitations issued or approved under sections 301(b)(2)(C) and (D); 304(b)(2); and 307(a)(2) of the Clean Water Act or more stringent discharge limitations and/or additional restrictions in the future to maintain the water quality integrity and the designated uses of the receiving water bodies based upon additional water quality studies and/or TMDL's, if the effluent standard, limitations, water quality studies or TMDL's so issued or approved:

- a) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- b) Controls any pollutant not limited in the permit; or
- c) Requires reassessment due to change in 303(d) status of waterbody; or
- d) Incorporates the results of any total maximum daily load allocation, which may be approved for the receiving water body.

Please be aware that the Department has the authority to reduce monitoring frequencies when a permittee demonstrates two or more consecutive years of permit compliance. Monitoring frequencies established in LPDES permits are based on a number of factors, including but not limited to, the size of the discharge, the type of wastewater being discharged, the specific operations at the facility, past compliance history, similar facilities and best professional judgment of the reviewer. We encourage and invite each permittee to institute positive measures to ensure continued compliance with the LPDES permit, thereby qualifying for reduced monitoring frequencies upon permit reissuance. If the Department can be of any assistance in this area, please do not hesitate to contact us. As a reminder, the Department will also consider an increase in monitoring frequency upon permit reissuance when the permittee demonstrates continued non-compliance.

Final effluent loadings (i.e. lbs/day) have been established based upon the permit limit concentrations and the design capacity of 0.19 MGD.

Effluent loadings are calculated using the following example:

$$\text{BOD: } 8.34 \text{ lb/gal} \times 0.19 \text{ MGD} \times 10 \text{ mg/l} = 16 \text{ lb/day}$$

At present, the **Monitoring Requirements, Sample Types, and Frequency of Sampling** as shown in the permit are standard for facilities of flows between 0.1 and 0.5 MGD.

Statement of Basis

LA0118966; AI 111355; PER20090001

Page 7

Effluent CharacteristicsMonitoring Requirements

	<u>Measurement</u>	<u>Sample</u>
	<u>Frequency</u>	<u>Type</u>
Flow	Continuous	Recorder
CBOD ₅	2/month	Grab
Total Suspended Solids	2/month	Grab
Ammonia-Nitrogen	2/month	Grab
Dissolved Oxygen	2/month	Grab
Fecal Coliform Bacteria	2/month	Grab
pH	2/month	Grab

XIII. TENTATIVE DETERMINATION:

On the basis of preliminary staff review, the Department of Environmental Quality has made a tentative determination to reissue a permit for the discharge described in this Statement of Basis.

XIV. REFERENCES:

Louisiana Water Quality Management Plan / Continuing Planning Process, Vol. 8, "Wasteload Allocations / Total Maximum Daily Loads and Effluent Limitations Policy," Louisiana Department of Environmental Quality, 2005.

Louisiana Water Quality Management Plan / Continuing Planning Process, Vol. 5, "Water Quality Inventory Section 305(b) Report," Louisiana Department of Environmental Quality, 1998.

Louisiana Administrative Code, Title 33 - Environmental Quality, Part IX - Water Quality Regulations, Chapter 11 - "Louisiana Surface Water Quality Standards," Louisiana Department of Environmental Quality, 2004.

Louisiana Administrative Code, Title 33 - Environmental Quality, Part IX - Water Quality Regulations, Subpart 2 - "The LPDES Program," Louisiana Department of Environmental Quality, 2004.

Low-Flow Characteristics of Louisiana Streams, Water Resources Technical Report No. 22, United States Department of the Interior, Geological Survey, 1980.

Index to Surface Water Data in Louisiana, Water Resources Basic Records Report No. 17, United States Department of the Interior, Geological Survey, 1989.

LPDES Permit Application to Discharge Wastewater, H2O Systems, Inc, Penn Mill Lakes STF, March 23, 2009.